


March 2015

To ensure your tap water is safe, clean and secure, Tucson Water conducts approximately 14,500 individual tests each year on the water in the main distribution system – before it reaches your home. Test results for key parameters are reported by 10 water quality zones for a water distribution system that covers some 375 square miles.

Main Water System



March 2015

To ensure your tap water is safe, clean and secure, Tucson Water conducts approximately 14,500 individual tests each year on the water in the main distribution system – before it reaches your home. Test results for key parameters are reported by 10 water quality zones for a water distribution system that covers some 375 square miles.

Main Water System

TEST RESULTS BY WATER QUALITY ZONE

Zones	Hardness (mg/L*) 55 SP	Sodium (mg/L*) 53 SP	Nitrate-N (mg/L*) 86 SP	Fluoride (mg/L*) 86 SP	pH Level (S.U.) 247 SP	Temperature (deg°F) 247 SP
1	239	67	1.56	0.43	7.9	74.1
2	243	69	0.94	0.37	8.0	73.5
3	233	66	1.18	0.42	8.0	73.5
4	245	69	0.83	0.35	7.9	74.1
5	239	67	0.98	0.38	8.0	72.8
6	241	68	0.91	0.36	8.0	73.2
7	241	67	1.00	0.38	8.0	73.3
8	209	57	1.97	0.60	7.8	74.1
9	219	62	1.55	0.51	7.8	75.2
10	255	72	1.17	0.37	7.9	75.1
Avg	235	66	1.18	0.42	7.9	73.7

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons SP = Sample Points S.U. = Standard Units


COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard
for positive
samples
Positive
results
247 samples



CHLORINE




March 2015

Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.

Catalina Water System

Catalina is a community partially served by Tucson Water. It has about 400 connections, supplying water to about 1,000 persons with water from two wells.



TEST RESULTS from 2 Sample Points

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (deg°F) 1 SP	pH Level (S.U.) 2 SP	Temperature (deg°F) 2 SP
87	25	0.44	0.51	8.1	70.1

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard for positive samples

Positive results




CHLORINE

Actual Average

0.7 mg/L


EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L



Corona de Tucson Water System

Corona de Tucson is a community located near Sahuarita and Houghton Roads, with about 2,600 connections supplying about 7,300 persons with water from three wells.



TEST RESULTS from 9 Sample Points

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 3 SP	Fluoride (deg°F) 3 SP	pH Level (S.U.) 9 SP	Temperature (deg°F) 9 SP
211	52	0.97	0.37	7.6	73.1

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons SP = Sample Points

COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard for positive samples

Positive results




CHLORINE

EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L

Actual Average
0.8 mg/L




March 2015

Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.

Diamond Bell Water System

Diamond Bell is a community located south and east of Sasabe Road and Diamond Bell Ranch Road respectively, with about 200 connections supplying about 570 persons with water from two wells.



TEST RESULTS from 1 Sample Point (SP)

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (deg°F) 1 SP	pH Level (S.U.) 1 SP	Temperature (deg°F) 1 SP
113	28	1.59	0.26	8.0	69.4

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard for positive samples
Positive result




CHLORINE

Actual
0.8 mg/L


EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L



Rancho del Sol Lindo & White Fence Farms Water System

Rancho del Sol Lindo is a community located southwest of Silverbell Road and North Trico Road. Rancho del Sol Lindo has about 1,000 connections, supplying about 2,700 persons with water from two wells.



TEST RESULTS from 3 Sample Points (SP)

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (deg°F) 1 SP	pH Level (S.U.) 3 SP	Temperature (deg°F) 3 SP
113	35	6.94	0.51	7.8	72.7

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard for positive samples
Positive results




CHLORINE

Actual Average
0.6 mg/L

EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L




March 2015

Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.

Sierrita Foothills Water System

This is a small community by the Three Points area, with 30 connections supplying approximately 75 people from one well.



TEST RESULTS from 1 Sample Point (SP)

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (deg°F) 1 SP	pH Level (S.U.) 1 SP	Temperature (deg°F) 1 SP
93	37	1.71	0.49	8.1	70.2

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard for positive samples

Positive result




CHLORINE

Actual
0.9 mg/L


EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L



Silverbell West Water System

The Silverbell West system has 83 connections serving approximately 230 people from one well.



TEST RESULTS from 1 Sample Point (SP)

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (deg°F) 1 SP	pH Level (S.U.) 1 SP	Temperature (deg°F) 1 SP
270	82	2.20	0.48	7.5	74.7

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard for positive samples

Positive result




CHLORINE

Actual 0.5 mg/L

EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L




March 2015

Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.


Thunderhead Ranch Water System

Thunderhead Ranch is a small subdivision west of Old Spanish Trail and about one and a half miles south of Irvington Road. It has about 57 connections supplying about 160 persons with water from two wells.



Tucson Police-Fire Academy Water System

The Police-Fire Academy, located south of Interstate 10 and east of Wilmot Road, was built in the late 1990s. One well supplies about 25 persons regularly, plus class members taught at this facility.



TEST RESULTS from 1 Sample Point

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (deg°F) 1 SP	pH Level (S.U.) 1 SP	Temperature (deg°F) 1 SP
91	13	2.07	0.18	8.2	73.9

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard for positive samples

Positive result




CHLORINE

Actual 0.4 mg/L

EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L



TEST RESULTS from 1 Sample Point (SP)

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (deg°F) 1 SP	pH Level (S.U.) 1 SP	Temperature (deg°F) 1 SP
196	42	0.79	0.31	7.7	75.9

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard for positive samples

Positive result




CHLORINE

Actual
0.8 mg/L

EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L




March 2015

Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.

Valley View Acres Water System

Valley View Acres is a small community located north of Hilltop Road, just west of Sandario Road, with about 150 connections supplying about 470 people with water from two wells.



TEST RESULTS from 1 Sample Point (SP)

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (deg°F) 1 SP	pH Level (S.U.) 1 SP	Temperature (deg°F) 1 SP
116	45	1.78	0.58	7.8	69.1

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

COLIFORM

The U.S. Environmental Protection Agency (EPA) has primary standards for levels of coliform bacteria and the disinfectant chlorine.

EPA standard for positive samples

Positive result



CHLORINE

EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L

Actual
0.8 mg/L

